

CERTIFICATE OF COMPLIANCE

Certificate Number 20180215-EX26640
Report Reference EX26640-20170526
Issue Date 2018-February-15

Issued to: Swastik Synergy Engineering Private Limited
No. 302 Business Suites
9 S. V. Road Santacruz West
Mumbai Maharashtra 400054 INDIA

**This is to certify that
representative samples of**

WET-CHEMICAL-SOLUTION EXTINGUISHING SYSTEM
UNITS

CON-FERNO Series, 9, 12, 15, 18, 21, 24, 27 and 30 Liter capacity, stored-pressure extinguishing system units. Unit is designed to discharge wet chemical solution from fixed nozzles for the extinguishment of fires in cooking appliances, hoods, plenums, filters, and ducts used for the ventilation of restaurant cooking equipment when such fires originate in the entrance of the ventilating equipment. For use at temperatures from +320F to +120°F. Operated by automatic means with manual back up. Includes the protection of deep fat fryers, range tops and woks.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL300, Fire Testing of Fire Extinguishing Systems for Protection of Commercial Cooking Equipment
UL1254, Pre-Engineered Dry Chemical Extinguishing System Units

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

