

### **Certificate of Product Approval**

Certificate Number: 1619b Issue: 01



# **Swastik Synergy Engineering Pvt. Ltd.**

53/2 & 53/3, Ajivali Khopoli-Pen Road Taluka: Khalapur

Post: Donvat, Dist.: Raigad, Khopoli

Maharashtra 410203

India

### **Products**

Direct Low Pressure (DLP) Application Fixed LPS 1666: Issue 1.0 **Fire Suppression Systems** 

(refer to attached appendix for details)

### **Standards**

Requirements and test procedures for the LPCB approval of direct low pressure (DLP) application fixed fire suppression systems, using heat sensitive pneumatic detection tubing, for the protection of small defined volume unoccupied enclosures.

This certificate and appendix is maintained and held in force through regular surveillance activities



Sarah Colwell

24 May 2021

24 May 2021



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.







## Appendix to Certificate No: 1619b Swastik Synergy Engineering Pvt. Ltd.

Synergy Firessense HFC-227ea (Synergy227) Direct Low Pressure (DLP) Application **Fixed Fire Suppression Systems** 

Product Name	Container Size	Description	Detector Tube	Ventilation (Enclosed or Open Vents)	Air Flow (Forced / Natural)	LPCB Ref. No.
SSE-SFS- 111000 - 01	1.2 Litre	1 kg HFC-227ea DLP system	P/N: SSE-FT-111006 6mm o/d	Enclosed & open options 4	Natural airflow only	1619b/01
SSE-SFS- 111000 - 02	2.3 Litre	2 kg HFC-227ea DLP system	P/N: SSE-FT-111006 6mm o/d	Enclosed & open options 4	Natural airflow only	1619b/02
SSE-SFS- 111000 - 04	5.2 Litre	4 kg HFC-227ea DLP system	P/N: SSE-FT-111006 6mm o/d	Enclosed & open options <sup>4</sup>	Natural airflow only	1619b/03

#### Notes:

- 1) Swastik Synergy Firessense HFC-227ea DLP Systems shall be configured, installed, serviced and maintained in accordance with:
  - Design, Installation, Operation and Maintenance Manual SSE-SFS-111000 Rev.05, Date: 11/02/2021
- 2) These systems are intended solely to provide enhanced local fire protection. They are not intended for use as whole room or building fire protection systems.
- 3) The systems use a single method for detection and delivery of the extinguishing agent to the activation point.
  - System operation pressure: 15 bar @ 21°C.
  - System operation temperature range: -20°C to +60°C.
- 4) The above systems may have air vents at low and/or high level (refer note 1).

This certificate and appendix is maintained and held in force through regular surveillance activities

S.A.Colwal

Sarah Colwell

24 May 2021

24 May 2021

Signed for BRE Global Ltd.



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.





Issue: 01